

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 2280-1357:100

Page 1 of 1

CATEGORY: Interior Coating Materials (Flame Spread)

LISTEE: PABCO, 1110 16 Road, Fruita, CO 81521
Contact: *Thomas Whitaker (970) 858-6211 Fax (970) 858-9641

DESIGN: SUPER FIRETEMP non-combustible, inorganic fiber board. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product identification and UL label.

APPROVAL: Listed as Class I fire retardant board for use on interior finish walls to reduce flame spread.

NOTE: For through penetration application, refer to CSFM Listing Cat. 4485 (Opening Protection-Firestopping). For other application, please consult the authority having jurisdiction for approval.

*Rev. 06-21-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager